



Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
AIR PRODUCTS & CHEMICALS	1		2			C	
1969 Palomar Oaks Way	2	1	2	2		C	
Carlsbad, CA 92011	3	1	2	2		C	
40 CFR Part 433 PSNS	4		2			C	
PT: pH adjustment							2,500
Required TTO certs submitted.							
ALPHATEC SPINE	1		1	1		C	
6110 Corte Del Cedro	2	1	1			C	
Carlsbad, CA 92011	3		1	1		C	
40 CFR Part 433 PSNS	4		1			C	
PT: evaporation, hauling							250
Required TTO certs submitted.							
CARLSBAD TECHNOLOGY, INC.	1	1	1			C	
5923 Balfour Court	2		1	1		C	
Carlsbad, CA 92008	3		2			C	
40 CFR Part 439, Subpart D PSNS	4		1	1		C	
PT: pH adjustment							60
CINTAS	1	1	1			C	
460 W. California Avenue	2		1	1		C	
Vista, CA 92083	3	1	1			C	
Industrial Laundry - Local Limits	4		1	1		C	
PT: none							55,000
CVI MELLEES GRIOT	1		2	2		C	
2051 Palomar Airport Road, Suite 200	2	1	2	2		C	
Carlsbad, CA 92011	3		2			C	
40 CFR Part 433 PSNS	4		2	2		C	
PT: pH adjustment, hauling							2,500
Required TTO certs submitted.							


Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
GE OSMONICS	1	1	1	3		C	
760 Shadowridge Drive	2	1	1	3		C	
Vista, CA 92083	3		1	7		C	
Mfr of water purification equip - Local Limits	4		1	3		C	
PT: hauling, equalization							45,000
GENERAL ELECTRONIC DEVICES							
320 S. Pacific Street	2					C	
San Marcos, CA 92078	3						
40 CFR Part 469, Subpart B PSNS	4						
PT: pH adjustment							5
Industry designated a NSCIU in March.							
HOCKING INTERNATIONAL	1	4	1	2		SNC	
970 Park Center Drive, #C	2	4	1	1		NC	
Vista, CA 92081	3	3	1	2	1	NC	
40 CFR Part 417	4	1	4	3		NC	
PT: pH adjustment, defoaming							350
Industry discovered discharging without a permit. Cease and Desist Order issued. New Class I permit issued in February. Industry subsequently caused foaming in collection system, impacted treatment plant by discharging dye, and violated local limit for oil & grease. NOVs and fines of \$9341.00 assessed. Industry installed evaporator and went zero-discharge in January 2009.							
HOLLANDIA DAIRY	1		1	9		C	
622 East Mission Road	2		1	3		C	
San Marcos, CA 92069	3	1	1	3		C	
Dairy & creamery - Local Limits	4		1	3		C	
PT: pH adjustment, filtration, hauling							36,000
HUBBARD ENTERPRISES							
2560-A Progress Street	2		1	1		C	
Vista, CA 92081	3		1			C	
40 CFR Part 433 PSNS	4		1	1		C	
PT: pH adjustment, hauling							1,650
Required TTO certs submitted.							


Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
HUES METAL FINISHING	1		1			C	
977 Linda Vista Drive	2		1	1		C	
San Marcos, CA 92078	3	1	1			C	
40 CFR Part 413, Subparts E&F PSES	4		1	1		C	
PT: chromium reduction, precip & settling							115
Required TTO certs submitted.							
HUGHES CIRCUITS	1		1			C	
540 S. Pacific Street	2		1	1		C	
San Marcos, CA 92078	3	2	1			C	
40 CFR Part 433 PSNS	4		1	1		C	
PT: pH adjustment, precipitation & settling							5,200
Required TTO certs submitted.							
ISIS PHARMACEUTICALS	1					C	
2282 Faraday Avenue	2					C	
Carlsbad, CA 92008	3					C	
40 CFR Part 439, Subpart C PSNS	4	1				C	
PT: hauling							0
Industry still undergoing clinical trials. No discharge of federally regulated wastewater to-date.							
J & D LABORATORIES	1	1	1			C	
2350 Oakridge Way	2		1	1		C	
Vista, CA 92081	3		2			C	
40 CFR Part 439, Subpart D PSNS	4		1	1		C	
PT: clarifier, centrifuge, oil skimmer							1,000
J & D LABORATORIES	1		1			SNC	
2640 Progress Drive	2	1	1	3		NC	
Vista, CA 92081	3		2			C	
40 CFR Part 439, Subpart D PSNS	4		1	1		C	
PT: clarifier, oil skimmer							4,200
Industry designated as being in SNC for repeated failure to report violations in a timely manner. NOV's issued and \$650.00 in fines assessed.							


Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
K & K LABORATORIES	1		1		1	SNC	
3305 Tyler Street	2	1	2	1	1	NC	
Carlsbad, CA 92008	3		2			NC	
40 CFR Part 439, Subpart D PSES	4		1	2	1	NC	
PT: sump							400
Two violations of the local limit for zinc and violation of the lower pH limit. NOVs issued and \$550.00 in fines assessed. Industry is cleaning sample sump more frequently and neutralizing cleaning wastewater prior to discharge.							
LIFE LABORATORIES	1	1	1	1	1	SNC	
1932 Kellogg Avenue	2	2	1	2		NC	
Carlsbad, CA 92008	3		1			C	
40 CFR Part 439, Subpart D PSNS	4	1	1	1		C	
PT: pH adjustment							20
Violation of the local limit for zinc. NOV issued and \$200.00 in fines assessed. Industry ceased operation in December and permit was rescinded.							
MACDERMID PRINTING SOLUTIONS	1	2	2	2		C	
260 S. Pacific Street	2	1	2	1		C	
San Marcos, CA 92078	3		2			NC	
40 CFR Part 465, Subparts A&C PSES	4		2			SNC	
PT: Cr reduction, precip & settling, pH adjust							28,000
Industry designated as being in SNC for failure to conduct required self-monitoring in third and fourth quarters.							
MERICAL, INC.	1		2	2		C	
2550 Pioneer Avenue	2	1	2	2	1	NC	
Vista, CA 92081	3		3	2	1	NC	
40 CFR Part 439, Subpart D PSNS	4		2	4	1	NC	
PT: none							1,500
One violation of the local limit for zinc at Sample Point #1 and two at Sample Point #2. NOVs issued and fines of \$750.00 assessed. Industry is vacuuming equipment prior to washing and cleaning sample point daily.							
METAL ETCH SERVICES	1		1	1		C	
1165 Linda Vista Drive, #106	2		1	1		C	
San Marcos, CA 92078	3		1			C	
40 CFR Part 433 PSNS	4	1	1	1		C	
PT: pH adjustment, hauling							150
Required TTO certs submitted.							


Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
NATURAL ALTERNATIVES	1		1			C	
1215 Park Center Drive	2	1	1	1		C	
Vista, CA 92081	3		2			C	
40 CFR Part 439, Subpart D PSNS	4		1	1		C	
PT: clarifier							3,700
NATURECEUTICAL INTERNATIONAL							
1240 Keystone Way	1		1			C	
Vista, CA 92081	2	1	1	1		C	
40 CFR Part 439, Subpart D PSNS	3						
PT: filtration, ion exchange, pH adjustment	4						15
Industry designated a NSCIU in July.							
ORTHO ORGANIZERS	1		1			C	
1822 Aston Avenue	2		1	1		C	
Carlsbad, CA 92008	3	1	1	1	2	NC	
40 CFR Part 471.105	4		1	3	7	SNC	
PT: precip & settling, pH adjustment, hauling							500
Industry reclassified from 40 CFR Part 433 to 471 and issued a new permit in August. Four violations of the federal daily max and three violations of the federal monthly average limits for copper. One violation of the federal daily max and federal monthly average limits for lead. NOV's issued and fines of \$1400.00 assessed. Industry ran out of the precipitant used for wastewater pretreatment and had trouble finding a new supplier. Once they obtained the product, sampling once again demonstrated compliance.							
ORTHODONTIC DESIGN & PRODUCTION	1	1					
1370 Decision Street, #D	2						
Vista, CA 92081	3						
40 CFR Parts 464.36 & 433.17	4	1	1	1		C	
PT: settling, evaporation, hauling							700
New Class I permit issued in November.							
PIERCAN USA	1	1	1			C	
180 Bosstick Boulevard	2		1	1		C	
San Marcos, CA 92069	3		1			C	
40 CFR Part 428, Subpart J PSNS	4		1	1		C	
PT: clarifier							20

Annual Pretreatment Program Report

1/1/08 - 12/31/08

 SIGNIFICANT INDUSTRIAL USERS	REPORTING QUARTER	NO. OF INSPECTIONS	AGENCY MONITORING	SELF-MONITORING	LIMIT VIOLATIONS	REPORTING QTR STATUS	FLOW RATE (GPD)
PRECISION CIRCUITS	1	1	2	1		NC	
1080 Joshua Way	2	2	1	1		C	
Vista, CA 92081	3	1	1	1		C	
40 CFR Part 433 PSNS	4	1	1	1		C	
PT: pH adjustment, precipitation & settling							750
Required TTO certs submitted.							
PRUDENTIAL OVERALL SUPPLY	1	1	2			C	
2485 Ash Street	2		1	1		C	
Vista, CA 92081	3	1	1			C	
Industrial Laundry - Local Limits	4	1	1	1		C	
PT: DAF, pH adjustment							18,000
SELECT SUPPLEMENTS	1		1			C	
5800 Newton Drive	2		1	1		C	
Carlsbad, CA 92008	3	1	1			C	
40 CFR Part 439, Subpart D PSNS	4		1	1		C	
PT: clarifier							1,600
SELTZER NUTRITIONAL TECHNOLOGIES	1		1	1		C	
2840 Loker Avenue East, #101	2		1	1		C	
Carlsbad, CA 92010	3	1	1	1	1	NC	
40 CFR Part 439, Subpart D PSNS	4		2			NC	
PT: pH adjustment							500
Violation of the local limit for zinc. NOV issued and \$100.00 in fines imposed. Industry replaced worn drain cover, which allowed product to leak into the drain.							
TECH M3	1						
1281 Activity Drive	2						
Vista, CA 92081	3						
40 CFR Part 433 PSNS	4	2				C	
PT: pH adjustment							500
New Class I permit issued in December. Required TTO cert submitted.							
VISTA INDUSTRIAL PRODUCTS	1		2	2		NC	
1395 Park Center Drive	2		2	2		C	
Vista, CA 92081	3	1	2	2		C	
40 CFR Part 433 PSNS	4		2	2		C	
PT: Cr reduction, precip & settling, pH adjust							1,900
Required TTO certs submitted.							